

# WPG41\*1 DIESEL GENERATING SET

## GENERATING SET RATINGS 50Hz – 1500rpm @ 0.8p.f.

Voltage	PF	RP	E	SP
V	kVA	kWe	kVA	kWe
415/240	38	30	41	33
400/230	38	30	41	33
380/220	38	30	41	33

# **PRODUCT FEATURES**

#### Engine

- •Cast iron gantry type structure block
- •One-piece forged crankshaft
- ·Separate cast iron cylinder heads and wet liners
- •Aluminum alloy pistons with oil cooling gallery

# **Cooling system**

•Radiator and hoses supplied directly mounted on the engine

•Thermostatically-controlled system with belt driven coolant pump and pusher fan

## **Fuel system**

•P type fuel injection pump and injector for higher inject pressure, for engines with electronic governor

## Lubrication system

- •Flat bottom large capacity oil pan
- •Spin-on full-flow lube oil filter



#### **Electrical system**

•12 Vdc electric starter motor and battery charging alternator

#### Air intake and exhaust system

•Special rear mounted air filter with restriction indicator

- ·Equipped with exhaust silencer
- •Exhaust manifold and turbocharger shield for heat isolating

#### Alternator

- •Brushless, 4 Pole, IP23 drip-proof revolving field design
- •Class H insulation and Class H temperature rise
- •Low reactance with 2/3 pitch windings on the stator
- •Direct-coupled by flexible disc
- •Sustained overcurrent >300% in 10 sec
- Direct drive centrifugal blower fan cooling

#### **Control module**

DSE control module is ideal for a wide control range to manage, monitor, and diagnose quickly and easily.
Display status message Provide protection Auto shutdown at fault detection



GENERATING SET SPECIFICATIONS				
Governor and regulation class	In accordar	nce to ISO 8528-5 Class G2 performance		
Phase number and connection		3 phase, 4 wires, Y-type		
Cooling method		Closed looped water-cooled		
Starting method		DC 12V Electric starter		
Steady-state voltage deviation		≤± 2.5%		
Steady-state frequency band ≤1.5%		≤1.5%		
ENGINE				
Brand / Model		Weichai / WP2.3D48E200		
Gross Power	kWm	ESP - 48 / PRP - 44		
Cylinder / Type / Aspiration		4 / In-line / Turbocharged and Aftercooled		
Bore x Stroke	mm	89 x 92		

rnm	89 X 92	
L	2.3	
	17.5:1	
kPa	ESP – 1670	
	L	L 2.3 17.5:1

	Liquid (water + 50% antifreeze)
L	8.4
°C	105
m³/min	102
С°	78 -105
g/kW.hr	≤ 0.4%
L	11.5
	Spin-on full flow filter
	m³/min °C



FUEL SYSTEM		
Type of fuel filter		Spin-on fuel filter
Min. internal diameter of the supply pipe	mm	10
Min. internal diameter of the return pipe	mm	10
Max. fuel return restriction	Bar	0.5
Max. fuel inlet temperature	°C	50
Fuel supply flow	L/hr	45
Fuel Consumption (Tolerance +3%)		
Rating	gr/k	Wh L/hr
100%ESP	20	05 11.7
100%PRP	204	4.3 10.7
75% PRP	20	3.3 8
50% PRP	20	6.6 5.4
25% PRP	24	9.4 3.3
EXHAUST SYSTEM		
Exhaust Gas temperature after the turbocharger	°C	650
Exhaust Gas flow	m³/min	ESP – 9.42/ PRP – 8.82
Max. Exhaust back pressure	mBar	80

ALTERNATOR		
Brand / Model	WEICHAI / WHA-37.5-4/0.4	LEROY-SOMER / TAL-A42-E
Rated Current	54A	54A
Coupling / No. of Bearing	Direct / Single	Direct / Single
Winding Pitch	2/3	2/3
Type of Excitation	Self-excitation	Self-excitation
Cooling type	Air	Air
Voltage regulation method	AVR	AVR
Insurance	Class H	Class H
Temperature rise	Class H	Class H
Protection Grade	IP23	IP23
Efficiency at 0.8p.f.@100% load	86.6%	86.5%

CONTROL MODULE	
Back-lit LCD display	
3 Phase generator and 3 Phase Mains monitoring	
Monitoring speed, frequency, voltage, current, oil pressure, coolant temperature and fuel level	
Display warning, shutdown and engine status information	
Hours counter provides accurate information for monitoring and maintenance.	0 3 3 2 3 2 3 2 3 2 3 2 3 2 3 2 3 2 3 2



# **Ratings definitions**

#### Emergency Standby Power (ESP):


Emergency Standby Power is the maximum power available for a varying load for the duration of a main power network failure. The average load factor over 24 hours of operation should not exceed 70% of the engine's ESP power rating.

Typical operational hours of the engine are 200 hours per year, with a maximum usage of 500 hours per year. This includes an annual maximum of 25 hours per year at the ESP power rating. No overload capability is allowed. The engine is not to be used for sustained utility paralleling applications.

#### Prime power (PRP):

Prime Power is the maximum power available for unlimited hours of usage in a variable load application. The average load factor should not exceed 70% of the engine's PRP power rating during any 24 hour period. An overload capability of 10% is available; however, this is limited to 1 hour within every 12 hour period.

Open genset



#### Silence genset



This outline drawing is to provide representative configuration details for Model series only. See respective model data sheet for specific model outline drawing number. Do not use for installation design

#### **Ddimension and Weight**

Structure	Model	Dim "A" mm	Dim "B" mm	Dim "C" mm	Dry wt.* kg
Open	WPG41F1	1600	807	1118	735
Silence	WPG41L1	2250	850	1100	1035

\* Note: Weights represent a set with standard features. See outline drawings for weights of other configurations.

## Codes and standards

ISO 9001	This generating set is designed and manufactured in facilities certified to ISO 9001.	ISO 8528	This generating set has been designed to comply with ISO 8528 regulation.
CE	The CE marking is only valid when equipment is used in a fixed installation application. Material compliance declaration is available upon request.		

For more information contact your local Weichai distributor or visit www.weichai.com